

ACE WATER WELLS
A Subsidiary of ACE Ventures, Inc.

P.O. Box 520090
 Big Lake, Ak. 99652
 (907) 357-7987 fax
 (907) 376-7987
aceh2o@mtaonline.net

WELL FLOW TEST REPORT

Location Peak Tozenhomes

Crew CH + Ted Durham

Subs _____

Date _____

Well Depth 141

Static level 79.79

Other 1600 meter Pump set 126

Clock Timer	Static (Static)	Static Static	GPM	Gallons Pumped	Recovery	Remarks
9:55	Static	Static				—
56	79.90	ON				
57	79.90		75+		ADJUSTING FLOW	
58	79.90				↓	
59	79.90		75			
10:00	79.90					—
05	79.89					
10	79.90					
15	79.94					
20	79.94					
25	79.90					
30	79.91					
35	79.90					
40	79.92					
45	79.91					
11:00	79.91					
15	91					
30	92					
45	92					
12:00	93					
12:15	91					
30	93					

Average Flow rate:
 Comments

891
 79
 —
 13

ACE WATER WELLS

A Subsidiary of ACE Ventures, Inc.

P.O. Box 520090

Big Lake, Ak. 99652

(907) 357-7987 fax

(907) 376-7987

aceh2o@mtaonline.net

WELL FLOW TEST REPORT

Location Peak Townhomes

Crew CH & Ted Durham

Subs _____

Date _____

Well Depth 141

Static level 79.79

Other _____

Clock Timer	Time (Min)	Static Level	GPM	Gallons Pumped	Recovery	Remarks
12:45	79.91					
13:00	.93					
13:30	.90					
14:00	.90					
14:30	.92					
15:00	.90					
15:30	.92					
16:00	.92					
16:30	.91					
17:00	.90					
17:30	.91					
17:45	.93					
	Recovery					
17:46	79.85					
47	79.82					
48	79.81					
50	79.80					
51	79.79					

Average Flow rate:
Comments